

Air Flow vs. Power Requirement

The following chart may be found in ASHRAE literature and in California building codes. It illustrates the relationship between Fan Speed, Air Flow and Power Requirement. Two Speed or Variable Speed EC motors are uniquely qualified to take advantage of this concept since their efficiency varies little with change of speed. This is because they are brushless DC motors where the commutation is controlled through a micro-processor rather than through changing hertz.

